

Installation Instructions For Type A Liquid Tight Conduit Connector

1. Slide gland subassembly onto conduit as shown in Figure 1.

2. Thread grommet into inside diameter of conduit as shown in Figure 2.

Hint: place grommet into connector body for easier gripping and subsequent threading into conduit.

3. Slide gland subassembly to end of conduit as shown in Figure 3; tighten gland nut onto body of connector.

Note: Gland sleeve will be tight and not slide fully to end. The gland sleeve will press itself over conduit as the gland nut is threaded on to the body. This tight fit creates a positive seal onto the conduit for added protection against leakage.

Attention:

Conduit diameter variations exist among each manufacturer. In some cases, the gland subassembly may not slide far enough to reach body threads. In those cases, partially unthread grommet just enough to allow gland to reach body threads. Once threading is engaged onto body, twist conduit and/or connector to reengage grommet fully then resume tightening gland nut subassembly.

Figure 1.





Figure 2.



Hint:





Figure 3.



WARRANTY: Thomas & Betts sells this product with the understanding that the user will perform all necessary tests to determine the suitability of this product for the user's intended application. Thomas & Betts warrants that this product will be free from defects in materials and workmanship for a period of two (2) years following the date of purchase. Upon prompt notification of any warranted defect, Thomas & Betts will, at its option, repair or replace the defective product or refund the purchase price. Proof of purchase is required. Misuse or unauthorized modification of the product voids all warranties.

Limitations and Exclusions: THE ABOVE WARRANTY IS THE SOLE WARRANTY CONCERNING THIS PRODUCT, AND IS IN LIEU OF ALL OTHER WARRANTIES EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, WHICH ARE SPECIFICALLY DISCLAIMED. LIABILITY FOR BREACH OF THE ABOVE WARRANTY IS LIMITED TO COST OF REPAIR OR REPLACEMENT OF THE PRODUCT, AND UNDER NO CIRCUMSTANCES WILL THOMAS & BETTS BE LIABLE FOR ANY INDIRECT, SPECIAL, INCIDENTAL OR CONSEQUENTIAL DAMAGES.