





INSTRUCTION SHEET

for Installing Duplex Devices to 4" Square Raised Surface Covers
Catalog Numbers: RS 2, RS 3, RS 8, RS 12, & RS 19 CC

INSTRUCTIONS:

1. The Nuts are located in the Duplex Receptacle holes on the Raised Surface Covers (see Figure 1).
2. Use a plier to break the Nuts from the cover at score mark (see Figure 2).
3. Orient the Nuts as shown in Figure 3 and mount the Nuts and the Duplex Receptacle to the Cover using the #6-32 screws supplied with the Duplex Receptacle (see Figure 3 & 4). Tighten screws securely.



Thomas & Betts

A Member of the ABB Group

WARRANTY: Thomas & Betts sells this product with the understanding that the user will perform all necessary tests to determine the suitability of this product for the user's intended application. Thomas & Betts warrants that this product will be free from defects in materials or workmanship for a period of two (2) years following the date of purchase. Upon prompt notification of any warranted defect, Thomas & Betts will, at its option, repair or replace the defective product. Misuse, misapplication or modification of Thomas & Betts Products immediately voids all warranties.

Limitations and Exclusions: THE ABOVE WARRANTY IS THE SOLE WARRANTY CONCERNING THIS PRODUCT, AND IS IN LIEU OF ALL OTHER WARRANTIES EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, WHICH ARE SPECIFICALLY DISCLAIMED. LIABILITY FOR BREACH OF THE ABOVE WARRANTY IS LIMITED TO COST OF REPAIR OR REPLACEMENT OF THE PRODUCT, AND UNDER NO CIRCUMSTANCES WILL THOMAS & BETTS BE LIABLE FOR ANY INDIRECT, SPECIAL, INCIDENTAL OR CONSEQUENTIAL DAMAGES.

Thomas & Betts Corporation
Memphis, Tennessee
www.tnb.com